

# SD1 Safety Disconnect

## SD1-SP-B, and SD1-DP-B Installation Instructions

**WARNING:** This product **MUST** be installed by qualified personnel only. It must be installed in compliance with local and national electrical codes and intrinsic safety standards. ICS is not responsible for damages or losses resulting from misuse or incorrect installation of this product.



The SD1 Safety Disconnect is used in fuel site sumps to automatically disconnect power to equipment and / or sound an alarm in the event of a fuel leak. It contains a chemical resistant 304 stainless steel float switch and housing. An included reset switch allows the service technician to reset the SD1 after the fault condition is corrected. The SD1 can also be reset by cycling power. Read through the instructions completely before beginning installation.

### I. PARTS IDENTIFICATION:

1. Open the packaging and verify that the required parts are present. Use the diagram at upper right to identify the SD1 components.

### II. INSTALLATION:

1. Disconnect power from the junction box at the circuit breaker.
2. Leave the relay module disconnected from the barrier. Locate an unused 3/4" threaded fitting in the junction box or light box and install the threaded barrier.
3. Connect the orange wires to the relay module using the attached connector. Make sure that the connector is oriented the correct direction and is firmly latched. The relay module remains inside the j-box or light box.
4. Route the float switch wire down to the sump. The float switch may sit on the bottom of the sump, or it may hang from the wire. To hang the float switch, use a wire tie to fasten the float switch wire to a pipe or conduit above the sump.
5. Select a location for the reset switch. It should be mounted in a location with easy access from the sump, as it will be used after the technician has corrected the source of the SD1 trigger. Route the reset switch wire to the desired location and fasten it with wire ties.
6. The SD1 can operate from either 110VAC or 220VAC. Connect the AC power supply to the wires as shown in the wiring connections table at right.
7. The relay module contains both normally open and normally closed contacts, allowing power to be disconnected, and an annunciator to be switched on if desired. Connect the relay module wires to the desired load and/or annunciator. The load should be connected to the normally open contacts. SD1-DP models have 2 relay modules and 2 sets of contacts. See attached wiring example. If you are unsure of the correct connection, contact ICS technical support.



### Wiring Connections:

#### Barrier

1. Black 110VAC HOT or 220VAC L1
2. White 110VAC Neutral or 220VAC L2


#### Relay Module:

1. Brown Common
2. Violet Normally Closed
3. Yellow Normally Open

### III. TESTING:

1. Connect AC power to the SD1 and the load. On power-up, the SD1 will monitor the status of the float switch and temperature sensor for several seconds, and then switch the relay module ON. This in turn will power the load. If the load does not power-on, make sure the float switch is in the down position and that the load is connected to the normally open contacts.
2. Manually raise the float switch for 5 seconds or more. The SD1 will de-energize the relay module, disconnecting power from the load. Note that once the SD1 is triggered, lowering the float switch again will not re-apply power to the load.
3. Manually lower the float switch.
4. Press and hold the reset switch for 5 seconds and release. The SD1 should re-energize the relay module, powering on the load again. *(The SD1 may also be reset by cycling the AC power off for 10 seconds and back on. Remember that the float switch must be in the down position before the relay module will be energized.)*

#### EXAMPLE WIRING



SD1 SPECIFICATIONS			
Barrier Specification		Relay Module Specification	
AC Input Voltage	90VAC to 280VAC	Max. Relay Switching voltage	300VAC
Operating Current Draw	30mA typical	Max Switching Current NC contacts	30A
Operating Temperature	-40 to 150 deg. F	Max Switching Current NO contacts	15A
Float Switch wire length	84 inches	Operating Temperature	-40 to 150 deg. F
Reset Switch wire length	48 inches		

As defined in article 501 – Class 1, Division 1, Groups C and D Locations of the National Electric Code, this apparatus and its interconnected components are intrinsically safe. Under normal or defined fault conditions this apparatus and its wiring cannot release sufficient energy to ignite a specific ignitable atmospheric mixture by opening, shorting, or grounding.

SD1 MODEL NUMBERS	
Model Number:	Description:
SD1-SP-B	SD1 Safety Disconnect, Single Relay, Rev. B
SD1-DP-B	SD1 Safety Disconnect, Dual Relay, Rev. B

**Integrated Control Systems Inc.**  
 1425 American Way, Cedar Hill, TX. 75104  
 PH: (972) 291-6064  
 FAX: (972) 291-5975  
[WWW.INTCONSYS.COM](http://WWW.INTCONSYS.COM)